



### DRINKING WATER LEAD AND COPPER MONITORING REPORT

Submit with Form EPA 5105

Page 1 of 2 pages

PWS Name: <i>Village of Ashville</i>	PWSID: <i>OH</i>	Analytical Laboratory Name: <i>MOSE ENVIRONMENTAL</i>	Laboratory Certification No.: <i>4039</i>
---	---------------------	--	--

List samples sequentially by Laboratory Sample Number

Date of Sample	Time Sample Taken	Laboratory Sample Number	Address of Sample Site <small>Example: 234 S Main St Town OH 40000</small>	Tap Type* and Location <small>Example: B 2<sup>nd</sup> floor</small>	Structure Type SFR, MFR or BLDG	Interior Plumbing Material Pb, CuPb>82, CuPb<83, or other	Service Line Material Pb, Cu, or other	Tier 1, 2, 3, or other	Lead Conc (ug/L)	Copper Conc (ug/L)
7/30	0700	0309204	255 Kraft ✓	K <del>at</del>	SFR	CuPb>82	CU	1	<50	<5.0
7/21	1000	0309200	465 Long ✓	MR	BLDG	CuPb>82	CU	2	<50	<5.0
7/21	1030	0309201	501 Long ✓	K	BLDG	CuPb>82	CU	2	<50	<5.0
7/21	1000	0309198	2943 St. Rt 752 ✓	B	BLDG	other	CU	2	<50	<5.0
7/21	1000	0309197	3625 St. Rt 752 ✓	MR	BLDG	CuPb>82	CU	2	<50	<5.0
7/21	1100	0309203	21 Hawthorne ✓	K	SFR	other	CU	1	<50	<5.0
7/21	0945	0309195	440 Poplar ✓	K	SFR	CuPb<83	CU	3	51	<5.0
7/08	0600	0309190	149 W. Main ✓	K	SFR	CuPb<83	CU	3	<50	<5.0
7/09	0700	0309185	291 Olive Ct ✓	K	SFR	CuPb>82	CU	1	<50	<5.0
7/08	0600	0309191	160 E. Station ✓	B	SFR	CuPb<83	CU	3	<50	<5.0

\*Tap type codes: B – bathroom cold water tap; D – drinking fountain; K – kitchen sink cold water tap; R – restroom sink cold water tap; O – other (with prior Ohio EPA acceptance)

Note: 1 mg/L = 1000 ug/L



### DRINKING WATER LEAD AND COPPER MONITORING REPORT

Submit with Form EPA 5105

Page 2 of 2 pages

PWS Name: <i>Village of Ashville</i>	PWSID: <i>OH</i>	Analytical Laboratory Name: <i>MAS</i>	Laboratory Certification No.: <i>4039</i>
---	---------------------	---	--

List samples sequentially by Laboratory Sample Number

Date of Sample	Time Sample Taken	Laboratory Sample Number	Address of Sample Site <small>Example: 234 S Main St Town OH 40000</small>	Tap Type* and Location <small>Example: B 2<sup>nd</sup> floor</small>	Structure Type SFR, MFR or BLDG	Interior Plumbing Material Pb, CuPb>82, CuPb<83, or other	Service Line Material Pb, Cu, or other	Tier 1, 2, 3, or other	Lead Conc (ug/L)	Copper Conc (ug/L)
7/30	1000	0309205	<del>26 E. Main</del> ✓	BS	BLDG	CuPb<83	CU	2	50	7.0
7/30	0945	0309204	3 E. Main ✓	B	BLDG	CuPb<83	CU	2	450	9.4
7/09	1200	0309193	17 Ashton Dr ✓	K	SFR	CuPb 782	CU	1	<50	<5.0
7/21	1015	0309199	320 Long ✓	K	BLDG	CuPb 782	CU	1	69	<5.0
7/08	0800	0309187	4 cherry ✓	BR	BLDG	CuPb<83	CU	2	70	<5.0
7/21	1045	0309202	91 W Main ✓	B	BLDG	CuPb<83	CU	2	72	<5.0
7/08	0700	0309186	180 E. Station ✓	B	SFR	CuPb<83	CU	3	83	<5.0
7/21	0900	0309196	286 Long ✓	B	BLDG	CuPb 782	Other	2	138	<5.0
7/08	0800	0309189	24 Long ✓	B	BLDG	CuPb 782	CU	2	218	10.1
7/17	0800	0309188	200 East Station ✓	BR	BLDG	CuPb<83	CU	2	233	<5.0

\*Tap type codes: B - bathroom cold water tap; D - drinking fountain; K - kitchen sink cold water tap; R - restroom sink cold water tap; O - other (with prior Ohio EPA acceptance)

Note: 1 mg/L = 1000 ug/L